

C-40

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 121

Dated: 03/02/2022

**FIRE SAFETY CERTIFICATE**

Certified that the R. R. Gita Bal Bharti Public School located at Jalebi Chowk, Sultan Puri, Delhi-110086, comprised of Ground + 02 upper floors has already been issued FSC by this department vide letter No. F.6/DFS/MS/2018/School/WZ/1933 dated 21.08.2018. The premises was re-inspected by the officer concerned of this department on 18.01.2022 in the presence of Sh. Bhogiram (UDC) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Educational "Group B" with effect from 03/02/2022 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subjected to compliance of the conditions under Rule 36 of the Delhi Fire Service Rules, 2010.

Issued on 03/02/2022 at New Delhi by


  
(Dhrampal Bhardwaj)  
Dy. Chief Fire Officer  
Tel:-01123414250

Copy to :-

1. The Principal, R. R. Gita Bal Bharti Public School located at Jalebi Chowk, Sultan Puri, Delhi-110086.
2. The Director of Education, Old Secretariat, Delhi

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner/ occupier shall submit a declaration every year in Form 'K' [sub rule (2) of Rule 38] provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction (Clause 2.9.2 of UBBL-2016) or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of Rule 37] along with a copy of this Certificate, six months prior to its expiry."



Manisha  
Principal  
R.R. Gita Bal Bharti Public School  
Sultan Puri, Delhi-41